

Date: 2024-07-24

SPITZER ENERGY COMPANY
4295 East Jurupa Street Suite 103A
Ontario CA 91761
USA

Ref: CU US + Canada Certificate

Type of Equipment : Power Storage Battery
Certificate No. : CU 72405846 0001
Report No. : CN24TGPQ 001
Engineer/Contact : Andy Chen
Standards : ANSI/CAN/UL 1973:2022

Dear Madame or Sir,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72405846 0001.

It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document. For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

With kind regards,

Certification Body

Jason Tang 

Enclosure

Certificate

Certificate no.

CU 72405846 0001

License Holder:

SPITZER ENERGY COMPANY
4295 East Jurupa Street Suite 103A
Ontario CA 91761
USA

Manufacturing Plant:

Futurepath Electronics
Technology (Dongguan)Co.,Ltd.
No.1 Deye Road, Changxiang Village
Changtian Industrial Park, Hengli
Town,
Dongguan
Guangdong
P.R. China

Report Number: CN24TGPQ 001

Client Reference: 168490357

Certification acc. to: ANSI/CAN/UL 1973:2022

Product Information

Certified Product: Power Storage Battery

Model Designation: SPZ 10.24KWh-WM

Technical Data:

Rated Energy	: 10.24kWh
Rated Voltage	: 51.2Vdc
Rated Capacity	: 200Ah
Operation Voltage Range:	44.8Vdc to 58.4Vdc
Rated Current	: 120A(0.6C)
Charging Temperature	: -5°C to 55°C
Discharging Temperature:	-15°C to 55°C
IP Rating	: 65

Remarks: Other Data: See Appendix (Constr. Data Form)

Appendix: 1


Date of issue: 2024-07-24
(yr/mo/day)

TUV Rheinland of North America, Inc.
400 Beaver Brook Rd, Boxborough, MA 01719
Tel +1 (978) 266 9500, Fax +1 (978) 266-9992

www.tuv.com